



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudraprayag
Ph (O): 01364-233226, E-mail: ee.ujs.rpg@gmail.com



TC-13230

ULR No.:TC1323025000000173F

Test Report ID: 313/UJS/DLWQTMLR/2025-26

Dated: 29/09/2025


TEST REPORT


Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School, Tilani, Rudraprayag.		
Product Description:	Drinking Water	Sample Description	One Water sample received from Shri Guru Ram Rai Public School, Tilani, Rudraprayag.
Discipline / Group:	Chemical/Water		
Reference Sample Identification:	DLWQTML/UJS/2025/Sept-05	Date of Start of Analysis: 27/09/2025	Date of End of Analysis : 29/09/2025
Date and Time of Sample Received: 27-09-2025 & 12:10 PM	Sample Collected by:	Organisation	

S.N	Name of Parameters	Results	Desirable Limit (BIS 10500:201 2)	Permissible Limit (BIS 10500:2012) in the Absence of alternative Source	Std. Test Method
1.	pH at 25 ⁰ C	6.79	6.5 to 8.5	No Relaxation	IS 3025 (Part-11)
2.	Turbidity, NTU, Max	2.78	1	5	IS 3025 (Part-10)
3.	Total Dissolved Solids (TDS), mg/L, Max	48.0	500	2000	IS 3025 (Part-16)

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing Laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****


Tested By
(Mohit kimothi)
Chemist


Review and Authorized By
(Er. Rewat Singh Rawat)
Technical Manager
Technical Manager
DLWQT&M Laboratory
Uttarkhand Jal Sansthan
Rudarprayg